



Hicksville Public Schools

Administration Building
200 Division Avenue
Hicksville, NY 11801-4800

Phone: 516-733-2100

Fax: 516-733-6584

Marianne Litzman
Superintendent of Schools

John O'Brien
District Clerk

November 12, 2020

Dear Families:

The District is committed to protecting the health and well-being of our students, teachers and staff. In compliance with the New York State Department of Health (NYS DOH) regulation titled *Lead Testing in School Drinking Water* (10 NYCRR Subpart 67-4), we recently performed an updated inventory of all water outlets in the school district and another round of sampling of all applicable water outlets. As you may be aware, these water outlets were previously tested in 2016.

Sampling of potable water outlets (water outlets used for cooking or drinking) was performed by our environmental consulting and testing firm. In an abundance of caution, the district also sampled non-potable outlets (water outlets not designated for cooking and/or drinking) throughout the school buildings. While not typically used as drinking water, it was decided that the sampling of these non-potable outlets be performed in the rare instance that a child might use them for drinking.

A total of 613 outlets were sampled district wide. Only 4 of the water outlets designated by the district for drinking or cooking revealed concentrations of lead above New York State's action level of 15 parts per billion. We would like to note that there has been no student access to these locations since the beginning of the school year. These outlets have been removed from service until remediation/repairs are performed and re-testing results document acceptable concentrations of lead.

All other outlets which revealed concentrations of lead above the New York State's action level of 15 parts per billion are not used for cooking and/or drinking and signs have been posted noting their restriction.

Details pertaining to these outlets can be referenced on the district's website. As always, if you have any questions, comments or concerns, please contact the facilities department at 516-733-2180.

Sincerely,

Marianne Litzman
Superintendent of Schools

Board of Education

Phil Heckler, President
Christopher Amato

Brenda Judson, Vice President
Sunita Manjrekar

Linda Imbriale

Carla Hoene, Secretary
Irene Carlomusto

Hicksville Union Free School District

19-44930

Outlet Number	AHERA Number	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result ppb	Current Status
Burns Avenue Elementary School & Shed							
HICKSV-0331	1042	Stage	Water Fountain-No Chiller	Potable	10/8/2020	40	Removed From Service, Pending Remediation
HICKSV-0328	1045	Room 150 Girl's Locker Room	Bathroom Faucet	Non-Potable	10/8/2020	42	Placarded for Non-Drinking Use Until Remediated
HICKSV-0326	1039	Room 133A	Spray Nozzle	Non-Potable	10/8/2020	22	Placarded for Non-Drinking Use Until Remediated
HICKSV-0332	1042	Stage	Water Fountain-No Chiller	Potable	10/8/2020	120	Removed From Service, Pending Remediation
Dutch Lane Elementary School & Shed							
HICKSV-1214	1003	122	Classroom Faucet	Non-Potable	10/9/2020	87	Placarded for Non-Drinking Use Until Remediated
HICKSV-1256	1043	150 Girl's Locker Room	Bathroom Faucet	Non-Potable	10/9/2020	51	Placarded for Non-Drinking Use Until Remediated
Fork Lane Elementary School & Shed							
HICKSV-1109	1031	Room 107 Kitchen	Kitchen Non Potable	Non-Potable	10/2/2020	26	Placarded for Non-Drinking Use Until Remediated
HICKSV-1086	1003	Room 122	Classroom Faucet	Non-Potable	10/2/2020	17	Placarded for Non-Drinking Use Until Remediated
HICKSV-1108	1031	Room 107 Kitchen	Hand Wash Only	Non-Potable	10/2/2020	37	Placarded for Non-Drinking Use Until Remediated
HICKSV-1081	1007	Girls Bathroom	Bathroom Faucet	Non-Potable	10/2/2020	19	Placarded for Non-Drinking Use Until Remediated
HICKSV-1111	1038	Boys Locker Room	Bathroom Faucet	Non-Potable	10/2/2020	130	Placarded for Non-Drinking Use Until Remediated
HICKSV-1117	1045	Room 150 Girls Locker Room	Bathroom Faucet	Non-Potable	10/2/2020	31	Placarded for Non-Drinking Use Until Remediated

Outlet Number	AHERA Number	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result ppb	Current Status
HICKSV-1122	1055	Room 147/148 Library	Classroom Faucet	Non-Potable	10/2/2020	40	Placarded for Non-Drinking Use Until Remediated
HICKSV-1127	1063	Room 143	Classroom Faucet	Non-Potable	10/2/2020	45	Placarded for Non-Drinking Use Until Remediated
HICKSV-1129	1061	Room 142	Classroom Faucet	Non-Potable	10/2/2020	140	Placarded for Non-Drinking Use Until Remediated
HICKSV-1090	1002	Room 126	Classroom Faucet	Non-Potable	10/2/2020	77	Placarded for Non-Drinking Use Until Remediated
Hicksville High School							
HICKSV-0511	1001	177 Music Room (Former Auto Shop)	Classroom Faucet	Non-Potable	10/2/2020	29	Placarded for Non-Drinking Use Until Remediated
HICKSV-0597	1048	C104 Girl's Locker Room	Water Fountain-No Chiller	Potable	10/1/2020	40	Removed From Service, Pending Remediation
HICKSV-0598	1048	C104 Girl's Locker Room	Water Fountain-No Chiller	Potable	10/1/2020	26	Removed From Service, Pending Remediation
Hicksville Middle School							
HICKSV-0996	1061G	Kitchen Dishwashing Area	Spray Nozzle	Non-Potable	10/3/2020	17	Placarded for Non-Drinking Use Until Remediated
Lee Avenue Elementary School & Shed							
HICKSV-0031	1029A	Boy's Locker Room Bathroom	Bathroom Faucet	Non-Potable	10/6/2020	89	Placarded for Non-Drinking Use Until Remediated
HICKSV-0074	1017	Room 110	Classroom Faucet	Non-Potable	10/6/2020	110	Placarded for Non-Drinking Use Until Remediated
Old Country Road Elementary School & Shed							
HICKSV-0389	1037	Girl's Locker Room	Bathroom Faucet	Non-Potable	10/7/2020	32	Placarded for Non-Drinking Use Until Remediated
Willet School (BOCES Occupied)							
HICKSV-0449	1004A1A	Principal's Office Coat Closet Bathroom	Bathroom Faucet	Non-Potable	10/8/2020	33	Placarded for Non-Drinking Use Until Remediated

Outlet Number	AHERA Number	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result ppb	Current Status
Woodland Elementary School & Shed							
HICKSV-0141	1033	Girl's Locker Room	Bathroom Faucet	Non-Potable	10/9/2020	33	Placarded for Non-Drinking Use Until Remediated